

## 8. Sentinel Hot & Cold Outlet Temperature Record

Cold water temperatures – check that temperature is below 20°C after running the water for up to 2 minutes

Hot water temperatures - check water temperature up to one minute to see if it has reached 50°C

Hot water supply temperature to TMV - check water temperature up to one minute to see if it has reached 50°C

Date	Location – Old School Building	Hot °C	Cold °C	TMV °C	Temperature satisfactory	Initial
01/05/2014	Visitors female wc	21.5	12.2	-	No	PS
01/05/2014	Cleaners Cupboard	21.7	12.7		No	PS
01/05/2014	Reception Tea Bay	57.4	12.8	-	Yes	PS
01/05/2014	Caretakers Workshop	21.9	12.2	-	No	PS

Date	Location – Scola Block	Hot °C	Cold °C	TMV °C	Temperature satisfactory	Initial
01/05/2014	Food tech room 26	50.4	17.8	-	Yes	PS
01/05/2014	Art room 33 – main block 2 <sup>nd</sup> floor	62.7	13.6	-	Yes	PS
01/05/2014	Room 20 - Science block	43.0	13.3	-	No	PS
01/05/2014	Disabled changing Room (mixer tap)	60.2	19.8	42.8	Yes	PS
01/05/2014	Practice music room	N/A	N/A	N/A	N/A -	PS
01/05/2014	Cleaners room	61.2	17.4		Yes	PS
01/05/2014	Female staff Room Toilet	61.6	13.0	-	Yes	PS

Date	Location – Sports Hall & Badminton	Hot °C	Cold °C	TMV °C	Temperature satisfactory	Initial
01/05/2014	*Ground level - Coffee shop & Kitchen	68.5	12.0	-	Yes	PS
01/05/2014	Lower level – Cleaners room	68.3	13.0	-	Yes	PS
01/05/2014	Lower level – 1 <sup>st</sup> aid room	No Access				PS

Date	Location – Science & Maths Block	Hot °C	Cold °C	TMV °C	Temperature satisfactory	Initial
01/05/2014	Store room	66.2	17.5		Yes	PS
01/05/2014	'right' classroom	65.9	22.3		No	PS

Date	Location – Sports Pavilion	Hot °C	Cold °C	TMV °C	Temperature satisfactory	Initial
01/05/2014	NA	NA	NA	NA	NA	PS

Date	Location – Main kitchen block	Hot °C	Cold °C	TMV °C	Temperature satisfactory	Initial
01/05/2014	Kitchen	62.5	12.4	-	Yes	PS

<b>Date</b>	<b>Location –New Rothely Nursery Building</b>	<b>Hot °C</b>	<b>Cold °C</b>	<b>TMV °C</b>	<b>Temperature satisfactory</b>	<b>Initial</b>
01/05/2014	Staff Room	57.5	12.4		Yes	PS
01/05/2014	Changing Room	60.5	12.5		Yes	PS
01/05/2014	Pre-School WC	57.8	12.4	36.7	Yes	PS

