

## 8. Sentinel Hot & Cold Outlet Temperature Record

Cold water temperatures – check that temperature is below 20°C after running the water for up to 2 minutes

Hot water temperatures - check water temperature up to one minute to see if it has reached 50°C

Hot water supply temperature to TMV - check water temperature up to one minute to see if it has reached 50°C

Date	Location – Old School Building	Hot °C	Cold °C	TMV °C	Temperature satisfactory	Initial
01/09/2014	Visitors female wc	60.0	16.5	-	Yes	PS
01/09/2014	Cleaners Cupboard	No Access				PS
01/09/2014	Reception Tea Bay	58.2	16.6	-	Yes	PS
01/09/2014	Caretakers Workshop	60.0	16.5	-	Yes	PS

Date	Location – Scola Block	Hot °C	Cold °C	TMV °C	Temperature satisfactory	Initial
01/09/2014	Food tech room 26	57.6	18.5	-	Yes	PS
01/09/2014	Art room 33 – main block 2 <sup>nd</sup> floor	64.5	18.1	-	Yes	PS
01/09/2014	Room 20 - Science block	55.2	17.1	-	Yes	PS
01/09/2014	Disabled changing Room (mixer tap)	61.5	19.1	41.4	Yes	PS
01/09/2014	Practice music room	N/A	N/A	N/A	N/A -	PS
01/09/2014	Cleaners room	No Access				PS
01/09/2014	Female staff Room Toilet	65.8	17.1	-	Yes	PS

Date	Location – Sports Hall & Badminton	Hot °C	Cold °C	TMV °C	Temperature satisfactory	Initial
01/09/2014	*Ground level - Coffee shop & Kitchen	71.2	15.8	-	Yes	PS
01/09/2014	Lower level – Cleaners room	72.7	15.9	-	Yes	PS
01/09/2014	Lower level – 1 <sup>st</sup> aid room	No Access				PS

Date	Location – Science & Maths Block	Hot °C	Cold °C	TMV °C	Temperature satisfactory	Initial
01/09/2014	Store room	64.1	18.9		Yes	PS
01/09/2014	'right' classroom	66.5	22.5		No	PS

Date	Location – Sports Pavilion	Hot °C	Cold °C	TMV °C	Temperature satisfactory	Initial
01/09/2014	NA	NA	NA	NA	NA	PS

Date	Location – Main kitchen block	Hot °C	Cold °C	TMV °C	Temperature satisfactory	Initial
01/09/2014	Kitchen	69.5	17.5	-	Yes	PS

Date	Location –New Rothely Nursery Building	Hot °C	Cold °C	TMV °C	Temperature satisfactory	Initial
01/09/2014	Staff Room	52.4	16.4		Yes	PS
01/09/2014	Changing Room	52.7	16.3		Yes	PS
01/09/2014	Pre-School WC	59.1	16.3	36.8	Yes	PS