

9. Hot & Cold Outlet Temperature Record

Date	Location	Hot °C	Cold °C	TMV °C	Initial
01/08/2014	Old school building– Upper school leaders room	60.3	19.7		PS
01/08/2014	Old school building – Boys WC	55.4	19.9		PS
01/08/2014	Scola science room 18–	60.4	18.5		PS
01/08/2014	Scola science room 21 –	54.1	18.1		PS
01/08/2014	Scola staff room kitchen	67.3	19.6		PS
01/08/2014	Scola Art room 34	63.2	22.2	43.5	PS
01/08/2014	Scola staff & visitors WC	51.0	17.5		PS
01/08/2014	Scola CDT WC	67.0	23.7	41.6	PS
01/08/2014	Maths block office - Mains water		17.5		PS
01/08/2014	Science left classroom		18.3		PS
01/08/2014	Main kitchen Pot Wash	66.5	19.4		PS
01/08/2014	Sports Hall/ badminton building –lower ground floor disabled WC	58.5	18.5	38.9	PS
01/08/2014	Sports Hall/ badminton building –lower ground staff WC	60.7	18.5	40.2	PS
01/08/2014	Sports Hall/ badminton building –ground floor cleaners room	66.2	18.0		PS
01/08/2014	Rothely New Nursery Toddlers WC	55.5	18.4	37.9	PS
01/08/2014	Rothely New Nursery Cleaners room	50.0	18.4		
01/08/2014	Rothely New Nursery Mixed WC		18.3	37.1	PS

Cold water temperatures – check that temperature is below 20°C after running the water for up to 2 minutes

Hot water temperatures - check water temperature up to one minute to see if it has reached 50°C

Hot water supply temperature to TMV - check water temperature up to one minute to see if it has reached 50°C