

9. Hot & Cold Outlet Temperature Record

Date	Location	Hot °C	Cold °C	TMV °C	Initial
15/12/2014	Old school building– Upper school leaders room	30.5	8.4		PS
15/12/2014	Old school building – Boys WC	61.0	9.5		PS
15/12/2014	Medical Room	31.5	8.9	28.5	PS
15/12/2014	Scola science room 21–	54.8	12.3		PS
15/12/2014	Scola staff room kitchen	62.5	14.7		PS
15/12/2014	Scola staff & visitors WC	55.5	13.8		PS
15/12/2014	Scola staff gents WC	53.0	22.0	43.0	PS
15/12/2014	Scola CDT WC	Water Heater Still Switched off	22.0		PS
15/12/2014	Maths block office - Mains water		13.0		PS
15/12/2014	Science left classroom		14.4		PS
15/12/2014	Sports Hall/ badminton building –lower ground staff WC	53.0	12.6	38.9	PS
15/12/2014	Sports Hall/ badminton building –ground floor cleaners room	58.3	9.9		PS
15/12/2014	Rothely New Nursery Toddlers WC	51.2	7.9	39.2	PS
15/12/2014	Rothely New Nursery Kitchen	52.0	8.7		PS
15/12/2014	Rothely New Nursery mixed WC		9.0	36.6	PS

Cold water temperatures – check that temperature is below 20°C after running the water for up to 2 minutes

Hot water temperatures - check water temperature up to one minute to see if it has reached 50°C

Hot water supply temperature to TMV - check water temperature up to one minute to see if it has reached 50°C