

9. Hot & Cold Outlet Temperature Record

Date	Location	Hot °C	Cold °C	TMV °C	Initial
02/01/2014	Old school building – deputy head	55.2	9.9	-	PS
02/01/2014	Old school building – staff WC	51.0	13.4		PS
02/01/2014	Old school building – Boys WC	54.8	9.9		PS
02/01/2014	Scola science room 21 –	59.8	9.4	-	PS
02/01/2014	Scola staff room kitchen	65.3	18.8		PS
02/01/2014	Scola CDT Toilet	70.4	23.5	40.4	PS
02/01/2014	Scola staff & visitors WC	23.5	26.8		PS
02/01/2014	Maths block office - Mains water		12.0	-	PS
02/01/2014	Science left classroom		10.7		PS
02/01/2014	Main kitchen Pot Wash	50.0	8.8		PS
02/01/2014	Sports Hall/ badminton building – lower ground staff WC	65.2	13.5	42.1	PS
02/01/2014	Sports Hall/ badminton building –ground floor cleaners	76.1	13.2		
02/01/2014	Sports Hall/ badminton building –ground floor disabled WC	63.7	13.6	41.4	PS
02/01/2014	Rothely New Nursery kitchen	52.1	10.2		PS
02/01/2014	Rothely New Nursery Pre-school classroom	54.5	9.1	38.9	PS
02/01/2014	Rothely New Nursery Toddlers WC	55.5	8.6	36.7	PS

Cold water temperatures – check that temperature is below 20°C after running the water for up to 2 minutes

Hot water temperatures - check water temperature up to one minute to see if it has reached 50°C

Hot water supply temperature to TMV - check water temperature up to one minute to see if it has reached 50°C