

9. Hot & Cold Outlet Temperature Record

Date	Location	Hot °C	Cold °C	TMV °C	Initial
03/07/2014	Old school building– deputy head	56.3	17.4		PS
03/07/2014	Old school building – Boys WC	54.6	17.4		PS
03/07/2014	Old school building – Girls WC	50.0	17.3		PS
03/07/2014	Scola science room 21 –	54.1	15.7		PS
03/07/2014	Scola staff room kitchen	66.3	18.5		PS
03/07/2014	Scola Art room 34	61.7	19.4	43.5	PS
03/07/2014	Scola staff & visitors WC	51.0	17.5		PS
03/07/2014	Scola Junior Girls WC	30.0	19.5		PS
03/07/2014	Scola CDT WC	66.5	23.0	41.5	PS
03/07/2014	Maths block office - Mains water		17.5		PS
03/07/2014	Science left classroom		16.5		PS
03/07/2014	Main kitchen Pot Wash	58.5	17.2		PS
03/07/2014	Sports Hall/ badminton building –lower ground floor disabled WC	62.3	16.8	34.0	PS
03/07/2014	Sports Hall/ badminton building –lower ground staff WC	63.2	17.3	39.2	
03/07/2014	Sports Hall/ badminton building –ground floor cleaners room	69.2	16.8		PS
03/07/2014	Rothely New Nursery kitchen	57.2	16.6		PS
03/07/2014	Rothely New Nursery Toddlers WC	62.0	16.7	39.2	PS
03/07/2014	Rothely New Nursery Rainbow classroom	50.0	16.5	39.2	
03/07/2014	Rothely New Nursery Mixed WC		16.7	34.0	PS

Cold water temperatures – check that temperature is below 20°C after running the water for up to 2 minutes

Hot water temperatures - check water temperature up to one minute to see if it has reached 50°C

Hot water supply temperature to TMV - check water temperature up to one minute to see if it has reached 50°C