

9. Hot & Cold Outlet Temperature Record

Date	Location	Hot °C	Cold °C	TMV °C	Initial
04/06/2014	Old school building – deputy head	37.6	15.2		PS
04/06/2014	Old school building – Boys WC	54.8	15.4		PS
04/06/2014	Scola science room 21 –	56.5	14.9		PS
04/06/2014	Scola staff room kitchen	65.5	18.7		PS
04/06/2014	Scola Art room 32	61.0	17.1	39.3	PS
04/06/2014	Scola staff & visitors WC	50.0	16.9		PS
04/06/2014	Scola CDT WC	70.1	19.9	41.8	PS
04/06/2014	Maths block office - Mains water		14.0		PS
04/06/2014	Science left classroom		15.8		PS
04/06/2014	Main kitchen Pot Wash	50.0	15.4		PS
04/06/2014	Sports Hall/ badminton building –ground floor disabled WC	61.4	15.4	41.3	PS
04/06/2014	Sports Hall/ badminton building –ground floor cleaners room	68.3	15.6		PS
04/06/2014	Rothely New Nursery kitchen	57.5	14.7		PS
04/06/2014	Rothely New Nursery Toddlers WC	62.0	15.3	37.0	PS
04/06/2014	Rothely New Nursery Mixed WC		14.9	34.0	PS

Cold water temperatures – check that temperature is below 20°C after running the water for up to 2 minutes

Hot water temperatures - check water temperature up to one minute to see if it has reached 50°C

Hot water supply temperature to TMV - check water temperature up to one minute to see if it has reached 50°C