

## 9. Hot & Cold Outlet Temperature Record

Date	Location	Hot °C	Cold °C	TMV °C	Initial
04/03/2014	Old school building – deputy head	41.5	9.4	-	PS
04/03/2014	Old school building – staff WC	51.2	12.7		PS
04/03/2014	Old school building – Boys WC	52.7	8.7		PS
04/03/2014	Old school building Girls WC	27.0	8.6		PS
04/03/2014	Scola science room 21 –	58.7	8.6	-	PS
04/03/2014	Scola staff room kitchen	67.1	14.8		PS
04/03/2014	Scola staff WC			33.0	PS
04/03/2014	Scola staff & visitors WC	21.0	18.1		PS
04/03/2014	Scola Junior Girls WC	22.0	19.0		PS
04/03/2014	Maths block office - Mains water		9.9	-	PS
04/03/2014	Science left classroom		9.8		PS
04/03/2014	Main kitchen Pot Wash	61.7	8.0		PS
04/03/2014	Sports Hall/ badminton building –ground floor disabled WC	62.5	14.5	41.9	PS
04/03/2014	Sports Hall/ badminton building –ground floor Boys WC	71.0		42.9	PS
04/03/2014	Sports Hall/ badminton building –ground floor Girls WC			42.7	PS
04/03/2014	Rothely New Nursery kitchen	55.0	9.9		PS
04/03/2014	Rothely New Nursery Rainbow classroom	48.9	10.0	38.9	PS
04/03/2014	Rothely New Nursery Toddlers WC	55.9	8.9	37.0	PS

Cold water temperatures – check that temperature is below 20°C after running the water for up to 2 minutes

Hot water temperatures - check water temperature up to one minute to see if it has reached 50°C

Hot water supply temperature to TMV - check water temperature up to one minute to see if it has reached 50°C