

9. Hot & Cold Outlet Temperature Record

Date	Location	Hot °C	Cold °C	TMV °C	Initial
01/05/2014	Old school building– deputy head	21.6	13.2		PS
01/05/2014	Old school building – Boys WC	58.0	13.0		PS
01/05/2014	Scola science room 21 –	40.2	13.1		PS
01/05/2014	Scola staff room kitchen	60.7	15.9		PS
01/05/2014	Scola Boys WC	51.0	18.4	43.0	PS
01/05/2014	Scola CDT WC	64.1	20.7	41.5	PS
01/05/2014	Maths block office - Mains water		11.8		PS
01/05/2014	Science left classroom		12.8		PS
01/05/2014	Main kitchen Pot Wash	55.2	12.7		PS
01/05/2014	Sports Hall/ badminton building –lower ground floor disabled WC	60.5	12.5	41.1	PS
01/05/2014	Sports Hall/ badminton building –lower ground floor staff WC	61.4	12.9	39.4	PS
01/05/2014	Sports Hall/ badminton building –ground floor cleaners room	61.4	12.9		PS
01/05/2014	Rothely New Nursery kitchen	57.4	12.6		PS
01/05/2014	Rothely New Nursery Rainbow classroom	51.7	12.7	39.2	PS
01/05/2014	Rothely New Nursery Toddlers WC	61.4	12.4	38.0	PS
01/05/2014	Rothely New Nursery Mixed WC		12.5	38.0	PS

Cold water temperatures – check that temperature is below 20°C after running the water for up to 2 minutes

Hot water temperatures - check water temperature up to one minute to see if it has reached 50°C

Hot water supply temperature to TMV - check water temperature up to one minute to see if it has reached 50°C