

9. Hot & Cold Outlet Temperature Record

Date	Location	Hot °C	Cold °C	TMV °C	Initial
07/11/2014	Old school building– Upper school leaders room	57.0	13.5		PS
07/11/2014	Old school building – Boys WC	53.0	13.3		PS
07/11/2014	Medical Room	55.6	13.8	41.4	PS
07/11/2014	Scola science room 17–	46.0	13.2		PS
07/11/2014	Scola staff room kitchen	64.0	14.9		PS
07/11/2014	Scola staff & visitors WC	20.0	14.5	43.0	PS
07/11/2014	Scola CDT WC	Water Heater Switched off	21.5		PS
07/11/2014	Maths block office - Mains water		14.8		PS
07/11/2014	Science left classroom		13.6		PS
07/11/2014	Sports Hall/ badminton building –lower ground staff WC	54.0	17.2	39.7	PS
07/11/2014	Sports Hall/ badminton building –ground floor cleaners room	57.0	14.4	36.6	PS
07/11/2014	Rothely New Nursery Busy Bees WC	62.0	12.9	39.0	PS
07/11/2014	Rothely New Nursery Kitchen	53.8	13.0		PS
07/11/2014	Rothely New Nursery mixed WC		12.8	37.0	PS

Cold water temperatures – check that temperature is below 20°C after running the water for up to 2 minutes

Hot water temperatures - check water temperature up to one minute to see if it has reached 50°C

Hot water supply temperature to TMV - check water temperature up to one minute to see if it has reached 50°C