

## 9. Hot & Cold Outlet Temperature Record

Date	Location	Hot °C	Cold °C	TMV °C	Initial
03/10/2014	Old school building– Upper school leaders room	59.7	16.2		PS
03/10/2014	Old school building – Boys WC	59.5	16.3		PS
03/10/2014	Old school building – girls WC	34.0	16.9		PS
03/10/2014	Scola art room 32–	58.0	17.8	37.7	PS
03/10/2014	Scola staff room kitchen	63.5	18.5		PS
03/10/2014	Scola gents WC	55.0	20.9	43.0	PS
03/10/2014	Scola CDT WC	Water Heater Switched off	21.3		PS
03/10/2014	Maths block office - Mains water		16.8		PS
03/10/2014	Science left classroom		16.7		PS
03/10/2014	Sports Hall/ badminton building –ground floor disabled WC	55.0	15.5	41.2	PS
03/10/2014	Sports Hall/ badminton building –first floor WC	53.5	15.9	36.6	PS
03/10/2014	Rothely New Nursery Toddlers WC	30.7	15.7	30.7	PS
03/10/2014	Rothely New Nursery Kitchen	30.0	15.5		PS

Cold water temperatures – check that temperature is below 20°C after running the water for up to 2 minutes

Hot water temperatures - check water temperature up to one minute to see if it has reached 50°C

Hot water supply temperature to TMV - check water temperature up to one minute to see if it has reached 50°C