

9. Hot & Cold Outlet Temperature Record

Date	Location	Hot °C	Cold °C	TMV °C	Initial
01/09/2014	Old school building– Upper school leaders room	60.5	17.4		PS
01/09/2014	Old school building – Boys WC	54.4	17.4		PS
01/09/2014	Old school building – Medical room	59.0	16.6	42.2	
01/09/2014	Scola science room 18–	31.5	17.2		PS
01/09/2014	Scola staff & visitors WC	28.8	17.2		PS
01/09/2014	Scola staff room kitchen	62.2	18.2		PS
01/09/2014	Scola boys WC	55.0	18.9	42.7	PS
01/09/2014	Scola CDT WC	Switched off	20.7		PS
01/09/2014	Maths block office - Mains water		16.7		PS
01/09/2014	Science left classroom		16.6		PS
01/09/2014	Main kitchen Pot Wash	57.5	17.4		PS
01/09/2014	Sports Hall/ badminton building –lower ground floor disabled WC	67.5	16.1	37.0	PS
01/09/2014	Sports Hall/ badminton building –lower ground staff WC	66.5	16.1	40.2	PS
01/09/2014	Sports Hall/ badminton building –ground floor cleaners room	72.0	15.8		PS
01/09/2014	Rothely New Nursery Busy Bees Classroom	52.0	19.9	40.7	PS
01/09/2014	Rothely New Nursery Early years WC	55.0	16.5	38.0	
01/09/2014	Rothely New Nursery Kitchen	52.6	16.4		PS

Cold water temperatures – check that temperature is below 20°C after running the water for up to 2 minutes

Hot water temperatures - check water temperature up to one minute to see if it has reached 50°C

Hot water supply temperature to TMV - check water temperature up to one minute to see if it has reached 50°C